

State Water Resources Control Board

March 13, 2018

(Via email and Certified Mail)
CERTIFIED MAIL
NO. 7017 2680 0000 6195 8794

Mr. Devon Toda
Compliance Manager
City of Santa Clara
1700 Walsh Avenue
Santa Clara, California 95050
dtoda@santaclaraca.gov

**SUBJECT: NOTICE OF VIOLATION; UNDERGROUND STORAGE TANK SYSTEMS
LOCATED AT CITY OF SANTA CLARA, STREET DEPARTMENT SOLID
WASTE DIVISION, 1700 WALSH AVENUE, SANTA CLARA**

Dear Mr. Toda:

As part of an initiative by the State Water Resources Control Board (State Water Board) to ensure compliance at government-owned and/or operated underground storage tank (UST) facilities in California, the State Water Board staff inspected the USTs at your facility on March 7, 2018, pursuant to authority under Health and Safety Code (H&SC), chapter 6.7, section 25289.

The State Water Board has identified the following violations pursuant to H&SC, chapter 6.7, and California Code of Regulations (CCR), title 23, chapter 16:

No.	Violation	Tank	Start Date	Stop Date	Regulation
1	Failure to Maintain Tank Information Form – The installation date for the diesel tank is missing in CERS.	Diesel	March 7, 2018	Ongoing	23 CCR 2711(a)

You are directed to correct the ongoing violation and submit compliance documentation to the State Water Board and Santa Clara City Fire Department within sixty (60) days from the date of this letter. Have your Designated Operator make specific notations in the next monthly designated operator report indicating the ongoing violation have been corrected. The monthly designated operator report and any associated photos must be submitted as proof of compliance.

Please send all compliance documentation to the following:

State Water Board

Mr. Joseph Lovesee
UST Enforcement Unit
Office of Enforcement
State Water Resources Control Board
801 K Street, Suite 2300
Sacramento, California 95814
joseph.lovesee@waterboards.ca.gov


Local CUPA

Mr. Frederick Chun
Assistant Fire Marshal
Santa Clara City Fire Department
1675 Lincoln Street
Santa Clara, CA 95050
fchun@santaclaraca.gov

Pursuant to Health and Safety Code, chapter 6.7, section 25299, the owner and operator of the tank(s) are liable for a penalty of \$500 to \$5,000 per tank, per day of violation. These penalties will continue to accrue until the violations have been corrected.

If you have any questions, please contact me at (916) 341-5551, or by email at amantha.henkel@waterboards.ca.gov.

Sincerely,

A handwritten signature in blue ink that reads "Amanda Henkel". The signature is fluid and cursive, with the first name "Amanda" and last name "Henkel" clearly distinguishable.

Amantha Henkel
Senior Environmental Scientist
UST Enforcement Unit
Office of Enforcement

cc: (via email only)

Mr. Frederick Chun
Assistant Fire Marshal
City of Santa Clara
fchun@santaclaraca.gov

Mr. Chris Fazzi
Maintenance Supervisor
City of Santa Clara
cfazzi@santaclaraca.gov